



CERT

DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NW-6102BP5481

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	ITAP S.p.A. Via Ruca n.19/21, I-25065 Lumezzane S.S. (BS)
Distributor <i>Vertreiber</i>	ITAP S.p.A. Via Ruca n.19/21, I-25065 Lumezzane S.S. (BS)
Product Category <i>Produktart</i>	stop valves for drinking water: ball valve (6102)
Product Description <i>Produktbezeichnung</i>	ball valve in straight through construction for the drinking water installation
Model <i>Modell</i>	ball valves GREEN 376, 377, 378, 379
Test Reports <i>Prüfberichte</i>	laboratory control test: KH 019/16 from 04.08.2016 (TZW) supplement test: KH 012/13 from 13.06.2013 (TZW) type testing: TA 017/08TA 024/08 from 22.02.2008 (TZW) KTW testing: KA 0203/15 from 14.08.2015 (TZW) hygienic testing: MO 246/16 from 17.05.2017 (TZW)
Test Basis <i>Prüfgrundlagen</i>	DVGW W 570-1 (01.03.2013) DIN EN 13828 (01.12.2003) UBA METALLE (15.03.2017) UBA KTW (07.03.2016) UBA ELASTOM (16.03.2016) DVGW W 270 (01.11.2007)
Date of Expiry / File No. <i>Ablaufdatum / Aktenzeichen</i>	26.11.2022 / 17-0460-WNV

70228-04-A-DE

09.10.2017 GI A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-05

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
376, 377, 378, 379	nominal pressure rating: PN 10 nominal diameter: DN 8	
376, 377, 378, 379	noise emission class: I nominal pressure rating: PN 10 nominal diameter: DN 10	
376, 377, 378, 379	noise emission class: I nominal pressure rating: PN 10 nominal diameter: DN 15	ABP: PA-IX 7616/I
376, 377, 378, 379	noise emission class: I nominal pressure rating: PN 10 nominal diameter: DN 20	ABP: PA-IX 7616/I
376, 377, 378, 379	noise emission class: I nominal pressure rating: PN 10 nominal diameter: DN 25	ABP: PA-IX 7616/I
376, 377, 378, 379	noise emission class: I nominal pressure rating: PN 10 nominal diameter: DN 32	ABP: PA-IX 7616/I
376, 377, 378, 379	nominal pressure rating: PN 10 nominal diameter: DN 40	
376, 377, 378, 379	nominal pressure rating: PN 10 nominal diameter: DN 50	

Type Variation <i>Ausführungsvariante</i>	Explanations <i>Erläuterungen</i>
376; 378	connections: at both sides internal thread
377; 379	connections: at one sides internal thread, at the other side external thread
378; 379	with short handle